

Number	16-001785-PR05 (NW-C01-05-en-01)
Owner	ALUMIL S.A. Industrial Area 61100 Kilkis Greece
Product	burglar resistant door
Designation	SD115
Details	Overall dimensions: 1400 x 2200 mm; Material: Aluminum profiles with thermal break; Type of opening: single leaf pivot; Attack side: Closing face according to EN 12519; Hardware: 3-point lock Secury Automatic 4 / GU as per DIN 18251 class 4 – Double cylinder 5012 / GU as per DIN 18252 Class 71 BZKB– Security furniture B- 75630-72-0-8 / GU as per DIN EN 1906 class 2 (digit 7) – 2 Pivot hinges / Alumil S.A
Special features	

Result

Burglary resistance according to EN 1627:2011-05



Class: RC 3

Basis *)

EN 1627:2011-05

*) and corresponding national versions
e.g. DIN EN

Test report: 16-001785-PR05 PB-C01-05-en-02

Representation



Instructions for use

The results obtained can be used as evidence in accordance with the above basis.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies. The document may only be published in full.

ift Rosenheim

07.02.2019



Konrad Querengässer, Dipl.-Ing. (FH)
Head of Testing Department
Security/Safety Testing



Fabian Kutscher, Dipl.-Ing. (FH)
Operating Testing Officer
Security/Safety Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 861-CC3BD