

Number	20-004222-PR01 (NW-C01-02-en-01)
Owner	ALUMIL S.A. Industrial Area 61100 Kilkis Greece
Product	External pedestrian doorset, single leaf, opening inwards
Designation	System: SD115 Shipping name: Pivot door
Details	Material Aluminium system with thermal break; Overall dimensions (W x H) 1400 x 2200; Closing condition closed and locked; Threshold: Designation S11536; System SD115; Material Aluminium system with thermal break; Lock: Manufacturer ALUMIL S.A., - Kilkis; Designation 450-51-113-01
Special features	Material compatibility must be taken into account. Material durability must be taken into account.

Result

Air permeability according to EN 12207:2016-12



Class: 3

Resistance to wind load according to EN 12210:2016-03



Class: C5/B5

Watertightness according to EN 12208:1999-11



Class: 7A

Basis *)

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions (e.g. DIN EN)

Test report: 20-004222-PR01 PB-C01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit. When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

19.11.2020



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: B05-77A20