

Number	17-001557-PR01 (NW-C01-02-en-01)
Owner	ALUMIL S.A. Industrial Area 61100 Kilkis Greece
Product	Single leaf external pedestrian doorset
Designation	system: SD77 shipping name: SMART DOORS
Details	Material Aluminium profile with thermal break; Overall dimensions (W x H) 875 mm x 2107 mm; Closing condition closed, fastened, latched and locked; Threshold: Designation S77774; System SD77; Material Aluminium profile with thermal break; Lock: Designation 450-31-531-10, SEC MR2 45/92/24U
Special features	Door frame seal at bottom additionally sealed with pourable sealant
Result	

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C4/B4

Watertightness according to EN 12208:1999-11



Class: 7A

ift Rosenheim
10.07.2017



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Thomas Krichbaumer
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions
e.g. DIN EN

Test report: 17-001557-PR01 PB-C01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: B73-B26A4