

Evidence of Performance

Burglar resistance

Test Report

No. 16-001785-PR04

(PB-C01-05-en-02)



Client	ALUMIL S.A. Industrial Area 61100 Kilkis Greece
Product	Burglar resistant Smart SD95 door RC 2
Designation	SMART DOORS
Overall dimensions (W x H)	1100 x 2200 mm
(Frame) Material, System	Aluminium profiles with thermal break , SD95
Attack side	Closing face as per EN 12519
Type of opening	Single leaf
Glazing	-/-
Hardware	3-point locking system Secury Automatic as per DIN 18251 Class 3 / GU – Security furniture Rosette / GU B- 75630-72-0-8 as per DIN EN 1906 class 2 (digit 7) – Double cylinder 5012 as per DIN 18252 Class 71 BZKB / GU – 2 hinges 360.77.950.33, ALUMIL SA
Installation	As per installation instructions by the client ALUMIL S.A.
Special features	-/-

Burglar resistance



RC 2

ift Rosenheim

13.06.2017

Konrad Querengässer, Dipl.-Ing. (FH)
Head of Testing Department
Security/Safety Testing

Florian Willer, Dipl.-Ing. (FH)
Operating Testing Officer
Security/Safety Testing

Basis

DIN EN 1627 : 2011
Pedestrian doorsets, windows,
curtain walling, grilles and
shutters – Burglar resistance –
Requirements and classification
DIN EN 1628 : 2011
DIN EN 1629 : 2011
DIN EN 1630 : 2011

Replaced Test Report No. 16-
001785-PR04 (PB-C01-05-en-
01) dated 11.11.2016

Representation



Instructions for use

This test report serves to
demonstrate the burglar re-
sistance

Validity

The data and results refer sole-
ly to the tested and described
specimen. The burglar re-
sistance test does not allow any
statement to be made on any
further characteristics of the
present structure regarding per-
formance and quality.

In deviation from the tested de-
sign the following size modifica-
tions are permitted:
in width +10% and -20%
in height +10% and -20%

Notes on publication

The ift- Guidance Sheet
"Conditions and Guidance for
the Use of ift Test Documents"
applies.

The cover sheet can be used
as an abstract.

Contents

The report contains a total of
32 pages

- 1 Object
 - 2 Procedure
 - 3 Detailed results
- Annex 1 (8 pages)
Annex 2 (2 pages)
Annex 3 (9 page)