

Number	18-002944-PR04 (NW-C01-02-en-02)
Owner	ALUMIL S.A. Industrial Area 61100 Kilkis Greece
Product	External pedestrian doorset
Designation	System: MD67 Shipping name: SMART DOORS
Details	Material Aluminium system with thermal break; Overall dimensions (W x H) 1100 x 2200 ; Closing condition closed, locked and secured; Face 2 Opening face; Threshold: Designation S67774; System S67; Material Aluminium system with thermal break; Lock: Designation 450-34-531-10
Special features	Material compatibility must be taken into account. Material durability must be taken into account.

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C4/B4

Watertightness according to EN 12208:1999-11



Class: 8A

Basis *)

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions
e.g. DIN EN

Test report: 18-002944-PR04 PB-C01-02-en-02

Replaces ift-Nachweis:
18-002944-PR04 NW-C01-02-en-01 dated 19.10.2018.

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 326-7B225

ift Rosenheim

10.01.2019



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Dimitrios Moustakidis
Operating Testing Officer
Building Component Testing