

Number	18-002944-PR05 (NW-C01-02-en-01)
Owner	ALUMIL S.A. Industrial Area 61100 Kilkis Greece
Product	External pedestrian doorset
Designation	System: MD67 Shipping name: SMART DOORS
Details	Material Aluminium system with thermal break; Overall dimensions (W x H) 1100 x 2200; Closing condition closed and locked; Threshold: Designation S67774; System S67; Material Aluminium system with thermal break; Lock: Designation 450-34-531-10
Special features	Position of locking. The vapour pressure equalisation of the glazing rebate has to be ensured. Material compatibility must be taken into account. Material durability must be taken into account.

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C4/B4

Watertightness according to EN 12208:1999-11



Class: E1350

ift Rosenheim

19.10.2018



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Dimitrios Moustakidis
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09

*) and corresponding national versions
e.g. DIN EN

Test report: 18-002944-PR05 PB-
C01-02-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: CC3-BD14B